

**Additional details to answers nos. 16, 25, 42, 51, 54, 57, 60.**

The Organiser of the Competition introduces additional details into the answers to the questions nos. 16, 25, 42, 51, 54, 57, 60 :

In accordance with the reading of the Rules of Procedure (pt. 3.7.4.D) and Appendix No. 15 incorporated therein ('The Requirements Applicable to the Museum Exhibition Area' – developer by Tempora), the ceiling over the entire permanent exhibition space should rise high (at approximately 12 m).

The rooms housing the permanent exhibition should be about 12m high counting from the lower edge of the ceiling carrying the storey above or from the ceiling of the flat roof, including the structural members of the latter (binding joist, trusses, spatial load-carrying structures, etc.) – as in Appendix No. 15 to the Rules of Procedure. If the structure of the proper ceiling enables laying the building's technical infrastructure, for which the technical space is anticipated, in between its elements, the height can be reduced as appropriate.

The temporary exposition rooms should be no lower than 4.80 m net.

It is not recommended to include daylight in the exhibition space lighting. The exhibition rooms should be fitted so as to enable installation of the following systems: audio-visual, sound amplification, and structural cabling. Separate rooms should be envisaged to house the technical equipment controlling the systems (computers, video-recorders, etc.). The option of having computer workstations should be provided for.